



Axio Power Canada Inc./
SunEdison Canada

Noise Study Report

For

Napanee TS Taylor Kidd
Solar Energy Project

H335467
Rev. 1
May 11, 2012

Report Disclaimer

This report has been prepared by Hatch Ltd. for the sole and exclusive use of Axio Power Canada Inc./SunEdison Canada (the "Client") for the purpose of assisting the Client in making decisions with respect to the development of a proposed solar photovoltaic project and shall not be (a) used for any other purpose, or (b) provided to, relied upon or used by any third party.

This report contains opinions, conclusions and recommendations made by Hatch Ltd. (Hatch), using its professional judgment and reasonable care. Any use of or reliance upon this report by the Client is subject to the following conditions:

- the report being read in the context of and subject to the terms of the agreement between Hatch and the Client, including any methodologies, procedures, techniques, assumptions and other relevant terms or conditions that were specified or agreed therein;
- the report being read as a whole, with sections or parts hereof read or relied upon in context;
- the conditions of the site may change over time (or may have already changed) due to natural forces or human intervention, and Hatch takes no responsibility for the impact that such changes may have on the accuracy or validity of the observations, conclusions and recommendations set out in this report; and
- the report is based on information made available to Hatch by the Client or by certain third parties; and unless stated otherwise in the Agreement, Hatch has not verified the accuracy, completeness or validity of such information, makes no representation regarding its accuracy and hereby disclaims any liability in connection therewith.

Project Report

May 11, 2012

Axio Power Canada Inc./SunEdison Canada Napanee TS Taylor Kidd Solar Energy Project

Noise Study Report

Table of Contents

Report Disclaimer

Executive Summary

| | |
|--|-----------|
| 1. Introduction | 1 |
| 1.1 Project Description | 1 |
| 1.2 Renewable Energy Approval Legislative Requirements | 1 |
| 2. Facility Description | 2 |
| 2.1 Project Location | 2 |
| 2.2 Acoustical Environment | 2 |
| 2.3 Life of Project..... | 4 |
| 2.4 Operating Hours | 4 |
| 2.5 Approach to the Study..... | 4 |
| 3. Noise Sources..... | 5 |
| 3.1 Substation Transformer..... | 5 |
| 3.2 Inverter Units | 5 |
| 3.3 Noise Summary Table | 6 |
| 3.4 Adjacent Solar Projects..... | 6 |
| 4. Points of Reception | 7 |
| 5. Mitigation Measures..... | 8 |
| 6. Impact Assessment | 9 |
| 6.1 Compliance with Performance Limits..... | 9 |
| 7. Conclusions and Recommendations | 14 |
| 8. Signatures..... | 14 |
| 9. References..... | 15 |

Appendices

| | |
|------------|--|
| Appendix A | Land Use Zoning Designation Plan, and Area Location Plan |
| Appendix B | Noise Sources |
| Appendix C | Noise Map from CADNA-A |
| Appendix D | CADNA-A Sample Calculations |

List of Tables

| Number | Title |
|---------------|--|
| Table 2.1 | General Project Description |
| Table 3.1 | Noise Source Summary (Day and Night Time) |
| Table 4.1 | Point of Reception Noise Impact from Individual Noise Sources of Napanee TS Taylor Kidd Solar Energy Project |
| Table 6.1 | Performance Limits (One-Hour L_{eq}) by Time of Day for Class 3 Areas |
| Table 6.2 | Calculated Sound Pressure Levels at POR (shaded rows correspond to representative POR) |
| Table 6.3 | Parcels Partially Affected by the Project's noise emission |

List of Figures

| Number | Title |
|---------------|------------------------|
| Figure 2.1 | Site Layout Plan |
| Figure 2.2 | CADNA-A Configurations |

Executive Summary

This report presents the results of the noise assessment study required for Solar Facilities under Ontario Regulation 359/09 and 521/10, as part of the Renewable Energy Approval (REA) Process.

Axio Power Canada Inc./SunEdison Canada (“Axio”) is proposing to develop a 10-Megawatt (MW) solar photovoltaic (PV) project Napanee TS Taylor Kidd Solar Energy Project (the “Project”). The Project is located on approximately 34 hectares (ha) of land on Part of Lots 27 and 28, Concession 1, Township of Loyalist (lower tier municipality), County of Lennox and Addington (upper tier municipality).

This Noise Assessment Report has been prepared based on the document entitled “Basic Comprehensive Certificates of Approval (Air) – User Guide” by the Ontario Ministry of the Environment (MOE, 2004). The sound pressure levels at the points of reception (POR) have been estimated using ISO 9613-2, implemented in the CADNA-A computer code. The performance limits used for verification of compliance correspond to the values for rural areas of 40 dBA. The results presented in this report are based on the best available information at this time. It is the intention that, in the detailed engineering phase of the project, certified noise data based on final plans and designs will confirm the conclusions of this noise study.

The results obtained in this study show that the sound pressure levels at POR, resulting from the Project operation, will not exceed MOE requirements for rural areas of 40 dBA.

1. Introduction

1.1 Project Description

Axio Power Canada Inc./SunEdison Canada (“Axio”) is proposing to develop a 10-megawatt (MW) solar photovoltaic (PV) project titled Napanee TS Taylor Kidd Solar Energy Project (the “Project”). The Project Location¹ is situated on approximately 34 hectares (ha) of land on Part of Lots 27 and 28, Concession 1, Township of Loyalist (lower tier municipality), County of Lennox and Addington (upper tier municipality).

The Project is proposed to be constructed on privately owned land that is currently undeveloped and covered primarily by woodland vegetation. The Project Site is located immediately north of Taylor-Kidd Boulevard, approximately 5.4 km south of the Village of Odessa and 2.9 km west of the community of Amherstview.

The proposed Project is a renewable energy generation facility which will use solar photovoltaic technology to generate electricity. Electricity generated by solar photovoltaic panels will be converted from Direct Current (DC) to Alternating Current (AC) by inverter units which will also step-up the voltage to 27.6 kV. A main transformer, located in the substation, will step up the voltage from the inverter units to 44 kV prior to being transmitted to the existing local distribution line. In order to meet the Ontario Power Authority (OPA)’s Feed-In-Tariff (FIT) Program requirements, a specific percentage of equipment will be manufactured in Ontario.

The construction of the Project will begin once the Renewable Energy Approval (REA) has been obtained and a power purchase agreement is finalized with the OPA. The construction period is estimated to be approximately 6 months. Operationally, the anticipated lifespan of the Project will be 30 years.

1.2 Renewable Energy Approval Legislative Requirements

Ontario Regulation 359/09 and 521/10, made under the Environmental Protection Act identify the Renewable Energy Approval (REA) requirements for green energy projects in Ontario. As per Section 4 of the Ontario Regulation 359/09 and its amendment (Ontario Regulation 521/10), ground mounted solar facilities with a name plate capacity greater than 12 kilowatts (kW) are classified as a Class 3 solar facility, and therefore, require an REA.

Section 13 of the Ontario Regulation 359/09 requires proponents of Class 3 solar facilities to complete a Noise Study Report in accordance with Appendix A of the publication “Basic Comprehensive Certificates of Approval (Air) – User Guide, 2004” by the Ministry of the Environment (MOE, 2004).

The Noise Study Report is to include a general description of the facility, noise sources and points of reception (POR), assessment of compliance, as well as all the supporting information relevant to the Project. A draft of the Noise Study Report must be made available to the public, the local municipality and identified Aboriginal communities, at least 60 days prior to the final public consultation meeting in accordance with Ontario Regulation 359/09 and 521/10.

¹ “Project Location” in the context of this study is an area occupied by the Project infrastructure.

2. Facility Description

The Project will utilize photovoltaic (PV) panels installed on fixed racking structures mounted on the ground. The PV panels generate DC electricity which will be converted to AC electricity by inverter units. The Project layout is based on 10 inverter units (i.e., building enclosures), each one containing two inverters and one medium-voltage transformer, and one 27.6-kV/44-kV/10-MVA substation transformer. The 27.6-kV power, collected from the inverter units, will be stepped-up to 44 kV by the substation transformer prior to being transmitted to the existing local distribution line.

Since the panels will be ground-mounted and the total nameplate capacity is over 12 kW, the Project is considered to be a Class 3 Solar Facility, according to the classification presented in Ontario Regulation 521/10.

Table 2.1 General Project Description

| | |
|----------------------------|----------------------------------|
| Project Description | Ground-mounted Solar PV, Class 3 |
| System Nameplate Capacity | 10-MW AC |
| Local Distribution Company | Hydro One Networks Inc. |

2.1 Project Location



The Project Location consists of undeveloped land predominately covered by woodland vegetation and zoned for industrial purposes totalling approximately 34 hectares, located immediately north of Taylor-Kidd Boulevard, approximately 5.4 km south of the Village of Odessa and 2.9 km west of the community of Amherstview. A railway line is situated to the north of the Project. Figure 2.1 shows the site layout plan while the zoning designation plan (Figure A.1) and area location plan (Figure A.2) drawings are included in Appendix A. 109 points of reception are located within 1.2 km from the Project Site² boundary.

2.2 Acoustical Environment

The Project Location is surrounded by woodlands, although it is currently zoned industrial. The spot sound measurements taken around the site showed sound pressure levels somewhat above those typical of rural areas (> 40 dBA). Traffic noise is perceived from Taylor Kidd Boulevard as well as Regional Road 33 (1 km to the south).

There are large industrial facilities located to the west (Bombardier Transportation) and south-west of the Project Site (Invista Polyester Plant), which contribute to the acoustical environment. A mineral processing facility is also located within 500 m from the project area (north-west). The facilities have railway access for loading-unloading of materials/goods, and the project is located next to the main railway lines (north). Consequently, train noise is perceptible in the area. No other industrial facilities or airports are found within 5 km of the site.

² "Project Site" in the context of this study is the complete area designated for the Project but not necessary occupied with the project infrastructure. Project Location is always contained within Project Site.



- LEGEND**
- Existing Features**
- # Noise Receptor
 - ⊕ Representative Noise Receptor
 - +— Railway
 - Road
 - Topographic Contour (5m interval)
 - Transmission Line
 - Watercourse
 - ▭ Parcel
 - ▭ Parrott's Bay Conservation Area
 - ▭ Wetland
- Proposed Project Components**
- ▭ Project Location
 - ▭ Project Site
 - + Inv# Inverter Unit
 - + SUB Substation Transformer
 - ⊙ Connection Point
 - Access Roads
 - Panel Layout
 - Transmission Line



Notes:
 1. OBM and NRVIS data downloaded from LIO with permission.
 2. Spatial referencing UTM NAD 83.
 3. Air Photos obtained from Cataraqui Region Conservation Authority, flown in 2008, scale 1:2000.

Figure 2.1
 Axio Power Canada Inc./SunEdison Canada
 Napanee TS Taylor Kidd Solar Project
Site Layout Plan



2.3 Life of Project

The expected life of the Project is 30 years. At that time (or earlier if the 20 year power purchase agreement is not extended), the Project will be decommissioned or refurbished depending on market conditions and/or technological changes.

2.4 Operating Hours

Solar PV facilities produce electricity during the daytime hours, when the sun rays are collected by the panels. After sunset, the facility will not receive solar radiation to generate any electricity. Under these conditions the inverters will not produce any noise and the transformers will be energized, but not in operation (no fans in operation).

2.5 Approach to the Study

The sound pressure levels at the POR were predicted using procedures from ISO 9613-2, which is a widely used and generally accepted standard for the evaluation of noise impact in environmental assessments. The sound power level for the inverter units was provided by the manufacturer while the sound power level for the substation transformer was estimated. The software package CADNA--A, which implements ISO-9613-2, was used to predict the noise levels at the closest POR. This numerical modeling software is able to simulate sound sources as well as sound mitigation measures taking into account atmospheric and ground attenuation. Some of the CADNA-A configurations used in the modeling are shown in Figure 2.2.

For modeling purposes, elevation contours and vegetation that blocks some of the POR from the sources were not included in the CADNA-A model. This conservative approach was applied in order to avoid including any barrier effects of ground surface or other temporary obstacles.




Figure 2.2 CADNA-A Configurations

3. Noise Sources

The main sources of noise from the Project will be 10 inverter units, each one containing two inverters and one medium-voltage transformer, and a substation containing the main step up transformer. Axio provided a layout of the solar PV facility (see Figure 2.1). The coordinates of each noise source are presented in Table B.1 of Appendix B.

All noise sources were modeled as non-directional point sources.

Switchgear and a small step-down transformer used for lighting, located at the substation, do not emit any significant noise and consequently have not been considered as sources of noise.

For the purpose of this study it is assumed that all inverters and transformers will be operating 24 hours at full capacity.

3.1 Substation Transformer

A step-up transformer that will step-up the 27.6-kV power to the 44 kV, required by the local distribution company, will be located in the substation. The transformer will be of oil-natural-air-forced (ONAF) type. The sound power levels resulting from the operation of the transformer were evaluated using data from NEMA TRI – 1993 (2000), and a 35-m² transformer surface area. This standard provides maximum sound level values for transformers, and manufacturers routinely meet this specification. Hence, the results based on NEMA may slightly overestimate the impact on POR since the actual transformer is expected to be quieter.

The NEMA levels were then converted into frequency spectra using empirical correlations for transformer noise (Crocker, 2007). This calculation is available in Figure B.1 of Appendix B.

Power transformers are considered by the MOE to be tonal noise sources. A 5-dB penalty was added to the sound power spectrum, as recommended by Publication NPC-104, “Sound Level Adjustments” for tonality. Table B.2 in Appendix B shows the frequency spectrum used to model the substation transformer. Also, typical dimensions for a 27-kV/44-kV/10-MVA transformer have been supplied by Magna Electric Corporation, as seen in Figure B.3. These dimensions are expected to be similar to the installed dimensions of the substation transformer.

3.2 Inverter Units

Axio will use ten SMA Sunny Central 1000MV (SC1000MV) inverter units in the Project. Each SC1000MV inverter unit comprises of two inverters and one medium voltage transformer contained in an e-house or enclosure (see Appendix B). The main sources of noise are the cooling/ventilation fans, the electrical components of the inverters and the medium-voltage transformer. It is assumed that the current configuration of the SC1000MV unit, as specified in Appendix B, will be modified, if required according the CADNA-A model, to have the following features: 1) all openings will be equipped with acoustical louvers (silencers); 2) all external walls will be soundproof (i.e., sound emissions through the walls will be significantly lower than the sound emissions through the louvers).

The installed capacity of each inverter unit is 1 MW. SMA provided third-octave noise data for the SC1000MV unit, which takes into account combined noise emissions from the two inverters and transformer (see Appendix B). The provided third octave spectrum was converted to a full octave

spectrum for use with CADNA-A model (calculations are available in Figure B.2 of Appendix B). A 5-dBA penalty was added to the frequency spectrum, as stipulated in Publication NPC-104, "Sound Level Adjustments," to allow for tonality. The frequency spectra used for SC1000MV units is shown in Table B.2, Appendix B.

Although for the modeling purposes it was assumed that the facility will operate 24 h at full capacity, in reality at night the facility will be idle. Under these conditions the inverters do not produce noise. The transformers are energized and make some magnetostrictive noise at a reduced level, but no cooling fans are in operation.

3.3 Noise Summary Table

A summary of the sound sources described above, including sound level, characteristics and proposed noise control measures, is presented in Table 3.1.

Table 3.1 Noise Source Summary (Day and Night Time)

| Source ID | Description | Total Sound Power Level (dBA) | Source Location | Sound Characteristics | Noise Control Measures |
|-----------|---|-------------------------------|-----------------|-----------------------|------------------------|
| Sub | 27.6-kV/44-kV/10-MVA Substation transformer | 90.8 | O | S-T | U |
| Inv1 | Sunny Central 1000MV inverter unit | 102.2 | O | S-T | E-S |
| Inv2 | Sunny Central 1000MV inverter unit | 102.2 | O | S-T | E-S |
| Inv3 | Sunny Central 1000MV inverter unit | 102.2 | O | S-T | E-S |
| Inv4 | Sunny Central 1000MV inverter unit | 102.2 | O | S-T | E-S |
| Inv5 | Sunny Central 1000MV inverter unit | 102.2 | O | S-T | E-S |
| Inv6 | Sunny Central 1000MV inverter unit | 102.2 | O | S-T | E-S |
| Inv7 | Sunny Central 1000MV inverter unit | 102.2 | O | S-T | E-S |
| Inv8 | Sunny Central 1000MV inverter unit | 102.2 | O | S-T | E-S |
| Inv9 | Sunny Central 1000MV inverter unit | 102.2 | O | S-T | E-S |
| Inv10 | Sunny Central 1000MV inverter unit | 102.2 | O | S-T | E-S |

Notes:

1. A 5-dBA penalty is included in this table.
2. Location: Inside building (I), Outside building (O).
3. Sound Characteristics: Steady (S), Tonal (T), Impulsive (I), Quasi-Steady Impulsive (QSI).
4. Noise Control: Silencer (S), Acoustic lining (A), Barrier (B), Lagging (L), Enclosure (E), Other (O), Uncontrolled (U).

3.4 Adjacent Solar Projects

To identify the adjacent solar projects Hatch’s internal database of solar projects and MOE records available in http://www.ene.gov.on.ca/environment/en/subject/renewable_energy/projects/index.htm were searched (May 8, 2012).

There are no POR that are within 1 km of equipment in the Project and any adjacent project. As a result, there are no adjacent projects included in this study.

4. Points of Reception

The POR used in this study were initially identified from the OBM and high resolution aerial photography dated 2009 within 1.2-km distance from the Project Site boundary. Following this, the potential noise receptors located closest to the Project Location were then visually verified during a site visit held in September 2010. Based on this, a number of additional receptors (residential buildings) that were observed at the time of the inspection were added to the model.

The total number of POR considered in this study, within a 1.2-km distance from the Project Site boundary, is 109 (see Figure A.1 and Figure A.2 in Appendix A). Three of these noise receptors, identified in Table 4.1, were chosen as representative receptors for evaluating the noise contribution from each individual source (i.e., the substation and 10 inverters). These three receptors were chosen in order to represent sound pressure level contributions on different areas around the Project Location. The complete set of results for all 109 noise receptors is provided in Table 6.2, with corresponding noise maps from CADNA-A included in Appendix C. For this study, the POR elevation above ground is 4.5 m.

Table 4.1 Point of Reception Noise Impact from Individual Noise Sources of Napanee TS Taylor Kidd Solar Energy Project

| Source ID | POR 1 | | POR 2 | | POR 4 | |
|-----------|--------------|-----------------------|--------------|-----------------------|--------------|-----------------------|
| | Distance (m) | Leq Sound Level (dBA) | Distance (m) | Leq Sound Level (dBA) | Distance (m) | Leq Sound Level (dBA) |
| Sub | 293 | 30.0 | 774 | 20.6 | 822 | 20.0 |
| Inv1 | 584 | 19.8 | 929 | 15.3 | 1393 | 11.2 |
| Inv2 | 491 | 21.4 | 902 | 15.6 | 1306 | 11.9 |
| Inv3 | 409 | 23.2 | 884 | 15.8 | 1228 | 12.5 |
| Inv4 | 311 | 25.7 | 871 | 15.9 | 1131 | 13.3 |
| Inv5 | 239 | 28.2 | 873 | 15.9 | 1057 | 14.0 |
| Inv6 | 616 | 19.3 | 645 | 18.8 | 1201 | 12.7 |
| Inv7 | 549 | 20.4 | 618 | 19.2 | 1105 | 13.6 |
| Inv8 | 498 | 21.3 | 606 | 19.4 | 1021 | 14.3 |
| Inv9 | 455 | 22.2 | 608 | 19.4 | 927 | 15.3 |
| Inv10 | 428 | 22.7 | 626 | 19.1 | 846 | 16.2 |

5. Mitigation Measures

Mitigation for operation of the solar facility has been modeled and shown to be feasible in the form of soundproof (i.e., sound emissions through the walls will be significantly lower than the sound emissions through the louvers) enclosures with acoustical louvers on all openings for all inverter units. The Noise Reduction and Sound Transmission characteristics of the acoustical louvers considered in this study are presented in Table B.3 of Appendix B. Technical specifications of the proposed louvers are included in Appendix B as well.

6. Impact Assessment

The purpose of the acoustic assessment report is to demonstrate that the facility is in compliance with the noise performance limits. The Project will be located in a Class 3 Area, based on the classification defined in Publication NPC-232 by the MOE. Class 3 area means a rural area with an acoustical environment that is dominated by natural sounds, having little or no traffic, such as an agricultural area.

Table 6.1 shows the performance limits set by the MOE for Class 3 Areas, according to Publication NPC-232.

Table 6.1 Performance Limits (One-Hour L_{eq}) by Time of Day for Class 3 Areas

| Time of Day | One Hour L_{eq} (dBA) Class 3 Area |
|----------------|---|
| 07:00 to 19:00 | 45.0 |
| 19:00 to 23:00 | 40.0 |
| 23:00 to 07:00 | 40.0 |

The solar facility will be operating during the daylight hours, that is, between 07:00 and 19:00 during most days of the year. However, in the summer months the sun may shine before 07:00 or until past 19:00. As such, during the summer the facility will be operating at the time when the applicable performance limit changes from 45 dBA to 40 dBA. Also, the transformers remain energized at night. In order to account for this the study assumes that the facility will be operating 24 hours and compares the impact from the facility with the 40-dBA limit. In reality, the cooling fans will not be in operation at night.

For this study, the overall ground attenuation coefficient was estimated to be 0.7. Appendix D includes a list of all the parameters used in the CADNA-A model to predict the sound pressure levels at the POR.

The modelling does not consider the effect of the solar panels on the predicted sound pressure levels at the points of reception. The solar panels may act as barriers to further reduce noise at the POR.

6.1 Compliance with Performance Limits

Table 6.2 presents the predicted sound pressure levels for the POR. Sound pressure contours at 4.5 m and 1.5 m are available in Figure C.1 and Figure C.2. Appendix D includes a detailed calculation log of the representative POR with the highest Sound Pressure Level.

Effect of the noise emissions at the POR was also assessed by intersecting the 40-dBA sound pressure contours calculated at 1.5 m above ground with 30-m radius circles placed around the POR (Figure C.2). The results show that none of the 30-m radius zones are affected by the noise emissions.

**Table 6.2 Calculated Sound Pressure Levels at POR (shaded rows correspond to representative POR)
Existing = Existing dwelling**

| ID | Description | Total Sound Pressure (dBA) | Performance Limit (dBA) | Height (m) | UTM Coordinates, NAD83 Zone 18 | | Min dist. to source (m) |
|----|-------------|----------------------------|-------------------------|------------|--------------------------------|---------|-------------------------|
| | | | | | X (m) | Y (m) | |
| 1 | Existing | 35.0 | 40.0 | 4.5 | 363386 | 4897369 | 239 |
| 2 | Existing | 28.6 | 40.0 | 4.5 | 364240 | 4897986 | 606 |
| 3 | Existing | 25.6 | 40.0 | 4.5 | 364448 | 4898146 | 860 |
| 4 | Existing | 25.3 | 40.0 | 4.5 | 364329 | 4896997 | 822 |
| 5 | Existing | 25.3 | 40.0 | 4.5 | 363857 | 4896702 | 797 |
| 6 | Existing | 25.1 | 40.0 | 4.5 | 363852 | 4896685 | 812 |
| 7 | Existing | 24.8 | 40.0 | 4.5 | 363817 | 4896648 | 841 |
| 8 | Existing | 24.5 | 40.0 | 4.5 | 364393 | 4896953 | 900 |
| 9 | Existing | 24.4 | 40.0 | 4.5 | 364410 | 4896960 | 910 |
| 10 | Existing | 24.3 | 40.0 | 4.5 | 364440 | 4896981 | 923 |
| 11 | Existing | 24.1 | 40.0 | 4.5 | 364480 | 4896999 | 948 |
| 12 | Existing | 24.1 | 40.0 | 4.5 | 364495 | 4897007 | 957 |
| 13 | Existing | 24.0 | 40.0 | 4.5 | 363880 | 4896575 | 926 |
| 14 | Existing | 23.9 | 40.0 | 4.5 | 364522 | 4897020 | 975 |
| 15 | Existing | 23.8 | 40.0 | 4.5 | 364546 | 4897032 | 988 |
| 16 | Existing | 23.8 | 40.0 | 4.5 | 363880 | 4896553 | 947 |
| 17 | Existing | 23.7 | 40.0 | 4.5 | 364579 | 4897063 | 998 |
| 18 | Existing | 23.7 | 40.0 | 4.5 | 364307 | 4896757 | 966 |
| 19 | Existing | 23.7 | 40.0 | 4.5 | 363898 | 4896543 | 961 |
| 20 | Existing | 23.6 | 40.0 | 4.5 | 364593 | 4897059 | 1012 |
| 21 | Existing | 23.6 | 40.0 | 4.5 | 363718 | 4896503 | 973 |
| 22 | Existing | 23.6 | 40.0 | 4.5 | 364325 | 4896757 | 978 |
| 23 | Existing | 23.4 | 40.0 | 4.5 | 364530 | 4896933 | 1025 |
| 24 | Existing | 23.4 | 40.0 | 4.5 | 364560 | 4896964 | 1035 |
| 25 | Existing | 23.4 | 40.0 | 4.5 | 364118 | 4896597 | 990 |
| 26 | Existing | 23.2 | 40.0 | 4.5 | 364599 | 4896988 | 1057 |
| 27 | Existing | 23.2 | 40.0 | 4.5 | 364183 | 4896607 | 1013 |
| 28 | Existing | 23.2 | 40.0 | 4.5 | 364218 | 4896626 | 1016 |
| 29 | Existing | 23.2 | 40.0 | 4.5 | 364043 | 4896532 | 1017 |
| 30 | Existing | 23.2 | 40.0 | 4.5 | 364278 | 4896657 | 1025 |
| 31 | Existing | 23.2 | 40.0 | 4.5 | 364127 | 4896569 | 1019 |
| 32 | Existing | 23.1 | 40.0 | 4.5 | 364264 | 4896645 | 1026 |
| 33 | Existing | 23.1 | 40.0 | 4.5 | 364103 | 4896552 | 1023 |
| 34 | Existing | 23.0 | 40.0 | 4.5 | 364565 | 4896911 | 1066 |
| 35 | Existing | 23.0 | 40.0 | 4.5 | 364489 | 4896821 | 1056 |
| 36 | Existing | 23.0 | 40.0 | 4.5 | 364503 | 4896835 | 1058 |
| 37 | Existing | 23.0 | 40.0 | 4.5 | 364463 | 4896793 | 1054 |
| 38 | Existing | 22.9 | 40.0 | 4.5 | 364528 | 4896847 | 1071 |
| 39 | Existing | 22.9 | 40.0 | 4.5 | 364485 | 4896794 | 1070 |

| ID | Description | Total Sound Pressure (dBA) | Performance Limit (dBA) | Height (m) | UTM Coordinates, NAD83 Zone 18 | | Min dist. to source (m) |
|----|-------------|----------------------------|-------------------------|------------|--------------------------------|---------|-------------------------|
| | | | | | X (m) | Y (m) | |
| 40 | Existing | 22.9 | 40.0 | 4.5 | 364602 | 4896923 | 1092 |
| 41 | Existing | 22.8 | 40.0 | 4.5 | 364616 | 4896925 | 1103 |
| 42 | Existing | 22.8 | 40.0 | 4.5 | 364052 | 4896493 | 1057 |
| 43 | Existing | 22.8 | 40.0 | 4.5 | 364648 | 4896968 | 1108 |
| 44 | Existing | 22.7 | 40.0 | 4.5 | 364683 | 4897007 | 1116 |
| 45 | Existing | 22.6 | 40.0 | 4.5 | 363596 | 4896381 | 1095 |
| 46 | Existing | 22.6 | 40.0 | 4.5 | 363630 | 4896382 | 1093 |
| 47 | Existing | 22.6 | 40.0 | 4.5 | 364620 | 4896899 | 1120 |
| 48 | Existing | 22.5 | 40.0 | 4.5 | 363607 | 4896372 | 1103 |
| 49 | Existing | 22.5 | 40.0 | 4.5 | 364720 | 4897019 | 1141 |
| 50 | Existing | 22.4 | 40.0 | 4.5 | 364737 | 4897044 | 1143 |
| 51 | Existing | 22.4 | 40.0 | 4.5 | 363591 | 4896358 | 1118 |
| 52 | Existing | 22.4 | 40.0 | 4.5 | 363560 | 4896356 | 1123 |
| 53 | Existing | 22.3 | 40.0 | 4.5 | 363575 | 4896345 | 1132 |
| 54 | Existing | 22.1 | 40.0 | 4.5 | 362879 | 4896512 | 1230 |
| 55 | Existing | 22.2 | 40.0 | 4.5 | 364766 | 4897027 | 1177 |
| 56 | Existing | 21.9 | 40.0 | 4.5 | 362380 | 4896945 | 1260 |
| 57 | Existing | 22.1 | 40.0 | 4.5 | 364877 | 4897257 | 1188 |
| 58 | Existing | 22.1 | 40.0 | 4.5 | 364859 | 4897205 | 1187 |
| 59 | Existing | 22.1 | 40.0 | 4.5 | 364875 | 4897236 | 1192 |
| 60 | Existing | 21.9 | 40.0 | 4.5 | 363072 | 4896387 | 1236 |
| 61 | Existing | 21.8 | 40.0 | 4.5 | 362892 | 4896454 | 1276 |
| 62 | Existing | 21.9 | 40.0 | 4.5 | 364845 | 4897108 | 1210 |
| 63 | Existing | 21.9 | 40.0 | 4.5 | 363475 | 4896296 | 1192 |
| 64 | Existing | 21.6 | 40.0 | 4.5 | 362280 | 4897042 | 1303 |
| 65 | Existing | 21.9 | 40.0 | 4.5 | 364835 | 4897081 | 1213 |
| 66 | Existing | 21.9 | 40.0 | 4.5 | 364818 | 4897044 | 1214 |
| 67 | Existing | 21.8 | 40.0 | 4.5 | 364841 | 4897070 | 1223 |
| 68 | Existing | 21.8 | 40.0 | 4.5 | 363483 | 4896280 | 1207 |
| 69 | Existing | 21.7 | 40.0 | 4.5 | 364872 | 4897112 | 1233 |
| 70 | Existing | 21.7 | 40.0 | 4.5 | 364948 | 4897304 | 1243 |
| 71 | Existing | 21.7 | 40.0 | 4.5 | 364898 | 4897149 | 1243 |
| 72 | Existing | 21.7 | 40.0 | 4.5 | 363482 | 4896263 | 1224 |
| 73 | Existing | 21.6 | 40.0 | 4.5 | 363068 | 4896342 | 1277 |
| 74 | Existing | 21.6 | 40.0 | 4.5 | 364913 | 4897172 | 1249 |
| 75 | Existing | 21.5 | 40.0 | 4.5 | 364935 | 4897199 | 1261 |
| 76 | Existing | 21.4 | 40.0 | 4.5 | 363359 | 4896249 | 1261 |
| 77 | Existing | 21.4 | 40.0 | 4.5 | 365020 | 4897432 | 1290 |
| 78 | Existing | 21.4 | 40.0 | 4.5 | 364930 | 4897133 | 1279 |
| 79 | Existing | 21.3 | 40.0 | 4.5 | 364962 | 4897194 | 1288 |
| 80 | Existing | 21.3 | 40.0 | 4.5 | 363310 | 4896238 | 1285 |
| 81 | Existing | 21.2 | 40.0 | 4.5 | 365030 | 4897393 | 1305 |

| ID | Description | Total Sound Pressure (dBA) | Performance Limit (dBA) | Height (m) | UTM Coordinates, NAD83 Zone 18 | | Min dist. to source (m) |
|-----|-------------|----------------------------|-------------------------|------------|--------------------------------|---------|-------------------------|
| | | | | | X (m) | Y (m) | |
| 82 | Existing | 21.2 | 40.0 | 4.5 | 364979 | 4897205 | 1300 |
| 83 | Existing | 21.1 | 40.0 | 4.5 | 365008 | 4897249 | 1315 |
| 84 | Existing | 21.0 | 40.0 | 4.5 | 365047 | 4897341 | 1332 |
| 85 | Existing | 20.9 | 40.0 | 4.5 | 365033 | 4897242 | 1341 |
| 86 | Existing | 20.8 | 40.0 | 4.5 | 362610 | 4896475 | 1407 |
| 87 | Existing | 20.8 | 40.0 | 4.5 | 365051 | 4897248 | 1357 |
| 88 | Existing | 20.7 | 40.0 | 4.5 | 363232 | 4896176 | 1367 |
| 89 | Existing | 20.7 | 40.0 | 4.5 | 365078 | 4897259 | 1380 |
| 90 | Existing | 20.6 | 40.0 | 4.5 | 365110 | 4897365 | 1389 |
| 91 | Existing | 20.6 | 40.0 | 4.5 | 365100 | 4897294 | 1393 |
| 92 | Existing | 20.6 | 40.0 | 4.5 | 365097 | 4897268 | 1397 |
| 93 | Existing | 19.6 | 40.0 | 4.5 | 362957 | 4896077 | 1564 |
| 94 | Existing | 19.5 | 40.0 | 4.5 | 362538 | 4896282 | 1605 |
| 95 | Existing | 19.5 | 40.0 | 4.5 | 365102 | 4896844 | 1559 |
| 96 | Existing | 19.4 | 40.0 | 4.5 | 365113 | 4896861 | 1561 |
| 97 | Existing | 19.4 | 40.0 | 4.5 | 365130 | 4896879 | 1567 |
| 98 | Existing | 19.4 | 40.0 | 4.5 | 365144 | 4896897 | 1571 |
| 99 | Existing | 19.3 | 40.0 | 4.5 | 365161 | 4896914 | 1579 |
| 100 | Existing | 19.3 | 40.0 | 4.5 | 365183 | 4896946 | 1585 |
| 101 | Existing | 19.3 | 40.0 | 4.5 | 365193 | 4896964 | 1587 |
| 102 | Existing | 19.3 | 40.0 | 4.5 | 365175 | 4896926 | 1586 |
| 103 | Existing | 19.2 | 40.0 | 4.5 | 365220 | 4896989 | 1602 |
| 104 | Existing | 19.1 | 40.0 | 4.5 | 365237 | 4897010 | 1610 |
| 105 | Existing | 19.0 | 40.0 | 4.5 | 365264 | 4897039 | 1624 |
| 106 | Existing | 19.0 | 40.0 | 4.5 | 365275 | 4897052 | 1630 |
| 107 | Existing | 19.0 | 40.0 | 4.5 | 365261 | 4897016 | 1630 |
| 108 | Existing | 18.9 | 40.0 | 4.5 | 365298 | 4897062 | 1648 |
| 109 | Existing | 18.7 | 40.0 | 4.5 | 365330 | 4897073 | 1675 |

In order to account for the potential noise impacts to vacant lots surrounding the Project Location (i.e., those that could have an inhabited building constructed on the lot at a future date), a comparison was made between the Zoning Designation (Figure A.1 in Appendix A), the noise receptors, land parcels surrounding the Project Location and the noise contours shown in Figure C.1 and Figure C.2 in Appendix C. The results from the comparison are summarized in Table 6.3 below and show that the 40-dBA noise contour partially encroaches onto two parcels surrounding the Project Location.

Table 6.3 Parcels Partially Affected by the Project's noise emission

| Parcels ID | PIN | Zoning | Description |
|------------|-----------|------------|--|
| PR01 | 451290207 | Industrial | Contains existing noise receptor |
| PR02 | 451320058 | Industrial | Contains no existing noise receptor(s) |

The noise receptor located on parcel PR02 was included in the CADNA-A model and determined to be compliant with the MOE performance limits.

As described in 1.(4)4. of Ontario Regulation 521/10, a noise receptor on a vacant lot (where no building permit has been issued) is considered to be the location ". . . at which a building would reasonably be expected to be located, having regard to the existing zoning by-law and the typical building pattern in the area . . .". The results from the comparison show that two parcels surrounding the Project Location are partially affected by the Project's noise emission. However, none of the affected parcels is considered a vacant lot because both parcels are presently zoned industrial and, thus, future development on them for residential use is not presently permitted.

Based on the above, the results show that all POR are compliant with MOE guidelines based on the performance limits of 40 dBA.

7. Conclusions and Recommendations

For the Napanee TS Taylor Kidd Solar Energy Project, the sound pressure levels at the POR have been estimated using the CADNA-A model, based on ISO 9613-2. The performance limits used for comparison correspond to Class 3 areas, with a 40-dBA threshold. Mitigation for operation of the Project has been modeled and shown to be feasible.

Based on the results obtained in this study, it is concluded that the sound pressure levels at the POR, resulting from the Project operation, will be below MOE requirements for Class 3 areas of 40-dBA at all times.


8. Signatures

Report Prepared By



Auret Basson, M.Eng., Mechanical EIT

Report Reviewed and Approved By



11 May 2012

Oleg Belashov, M.A.Sc., P.Eng.

9. References

Ontario Regulation 359/09. Environmental Protection Act. Renewable Energy Approvals Under Part V.0.1 of the Act.

Ontario Regulation 521/10 made under Environmental Protection Act amending O.Reg. 359/09.

Ministry of the Environment (MOE). 2004. Basic Comprehensive Certificates of Approval (Air) – User Guide (Appendix A). Environmental Assessment and Approvals Branch.

Handbook of Noise and Vibration Control; Malcolm J. Crocker, 2007;

IEEE. 2006. C57.12.90-2006: Standard Test Code for Liquid-Immersed, Power and Regulating Transformers. pp 64 to 76.

Ministry of the Environment (MOE). 1997. Noise Assessment Criteria in Land Use Planning. Publication LU-131. Ontario Ministry of the Environment. 12 pp + Annex.

MOE. 1995. Sound Level Limits for Stationary Sources in Class 1 & 2 Areas (Urban). Publication NPC-205. Ontario Ministry of the Environment. 6 pp + Annex.

MOE. 1995. Sound Level Limits for Stationary Sources in Class 3 Areas (Rural). Publication NPC-232. Ontario Ministry of the Environment. 8 pp + Annex.



NEMA. 2000. Standards Publication No. TR 1-1993 (R2000): Transformers, Regulators and Reactors. National Electrical Manufacturers Association. 31 pp. (This reference probably not needed now).

International Organization for Standardization (ISO). Standard 1996-1: Description, Measurement and Assessment of Environmental Noise – Part 1: Basic Quantities and Assessment Procedures.

International Organization for Standardization (ISO). Standard 1913-2:Acoustics – Attenuation of sound during propagation outdoors – Part 2: General Method of Calculation.

Appendix A

**Land Use Zoning Designation Plan,
and Area Location Plan**




Legend

- Inv# Inverter Unit
- Sub Substation Transformer
- # Noise Receptor
- # Representative Noise Receptor
- Road
- Railway
- Watercourse
- Parcel
- Waterbody
- Wetland
- Project Site
- 1200m Envelope
- Zone Boundary

Zones

- A Agriculture
- D Future Development
- RU Rural
- R Residential
- SR Shoreline Residential
- M1 Light Industrial
- M3 General Industrial
- M4 Extractive Industrial
- EP Environmental Protection
- OS Open Space





1:20,000



Notes:
 1. OBM and NRVIS data downloaded from LIO with permission.
 2. Spatial referencing UTM NAD 83.
 3. Land use information obtained from Loyalist Township, Schedule A, C, D, 2010.


Figure A.1
 Axiom Power Canada Inc./SunEdison Canada
 Napanee TS Taylor Kidd Solar Project
Land Use Plan





Legend

- Inv# Inverter Unit
- Sub Substation Transformer
- # Noise Receptor
- Representative Noise Receptor
- - - 1200 m Envelope
- Existing Transmission Line
- Railway
- Road
- Solar PV Panels
- Topographic Contour (5m interval)
- Watercourse
- Authorized Aggregate Site
- Parcel
- Parrott's Bay Conservation Area
- Project Site
- Waterbody
- Wetland
- Wooded Area



Notes:
 1. OBM and NRVIS data downloaded from LIO with permission.
 2. Spatial referencing UTM NAD 83.

Figure A.2
 Axiom Power Canada Inc./SunEdison Canada
 Napanee TS Taylor Kidd Solar Project
Area Location Plan



Appendix B

Noise Sources

Table B.1 Point Sources Used in CADNA-A, Includes Tonality Penalty of 5.0-dBA.

| Source ID | Description | Spectra ID | Total Sound Power Level - 24 Hours (dBA) | Correction - 24 Hours (dBA) | Height (m) | UTM Coordinates, NAD83 Zone18 (m) | |
|-----------|---|------------------|--|-----------------------------|------------|-----------------------------------|---------|
| | | | | | | X | Y |
| Sub | 27.6-kV/44-kV/10-MVA Substation transformer | Transformer10MVA | 90.8 | 5.0 | 3.0 | 363660 | 4897475 |
| Inv1 | Sunny Central 1000MV inverter unit | SC1000MV | 102.2 | 5.0 | 3.5 | 363312 | 4897949 |
| Inv2 | Sunny Central 1000MV inverter unit | SC1000MV | 102.2 | 5.0 | 3.5 | 363347 | 4897858 |
| Inv3 | Sunny Central 1000MV inverter unit | SC1000MV | 102.2 | 5.0 | 3.5 | 363381 | 4897778 |
| Inv4 | Sunny Central 1000MV inverter unit | SC1000MV | 102.2 | 5.0 | 3.5 | 363426 | 4897678 |
| Inv5 | Sunny Central 1000MV inverter unit | SC1000MV | 102.2 | 5.0 | 3.5 | 363459 | 4897597 |
| Inv6 | Sunny Central 1000MV inverter unit | SC1000MV | 102.2 | 5.0 | 3.5 | 363596 | 4897949 |
| Inv7 | Sunny Central 1000MV inverter unit | SC1000MV | 102.2 | 5.0 | 3.5 | 363636 | 4897858 |
| Inv8 | Sunny Central 1000MV inverter unit | SC1000MV | 102.2 | 5.0 | 3.5 | 363671 | 4897778 |
| Inv9 | Sunny Central 1000MV inverter unit | SC1000MV | 102.2 | 5.0 | 3.5 | 363711 | 4897688 |
| Inv10 | Sunny Central 1000MV inverter unit | SC1000MV | 102.2 | 5.0 | 3.5 | 363742 | 4897607 |

Table B.2 Frequency Spectra Used for Modelling the Noise Sources, Not Including Tonality Penalty.

| Spectra ID | Octave Spectrum (dBA) | | | | | | | | | | |
|------------------|-----------------------|------|------|------|------|------|------|------|------|------|-------|
| | 31.5 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | A | lin |
| Transformer10MVA | 43.0 | 62.2 | 74.3 | 76.8 | 82.2 | 79.4 | 75.6 | 70.4 | 61.3 | 85.8 | 94.4 |
| SC1000MV | | 64.8 | 78.9 | 93 | 91.6 | 90.1 | 87.6 | 79.9 | 65.4 | 97.2 | 103.7 |

Table B.3 Noise Reduction and Sound Transmission Characteristics of the Acoustical Louvers.

| Name | Octave Spectrum (dBA) | | | | | | | | | |
|------------------|-----------------------|----|-----|-----|-----|------|------|------|------|--|
| | 31.5 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | |
| Greenheck Louver | 0 | 10 | 10 | 12 | 16 | 23 | 18 | 0 | 0 | |



Efficient

- Without low-voltage transformer: greater plant efficiency due to direct connection to the medium-voltage grid

Turnkey Delivery

- With medium-voltage transformer and concrete substation for outdoor installation

Optional

- Medium-voltage switchgear systems for a flexible structure of large solar parks
- AC transfer station with measurement

- Medium-voltage transformers for other grid voltages (deviating from 20 kV)


**SUNNY CENTRAL for Direct medium-voltage feed-in
800MV / 1000MV / 1250MV**

High-performance medium-voltage station

For even more power: Two powerful Sunny Central HE inverters are components of a medium-voltage station (MV) which feeds directly into a shared medium-voltage transformer. In this way, for example, two Sunny Central 630HE inverters are combined into a powerful Sunny Central 1250MV station. The advantage: By removing the need for the low-voltage transformer, the plant operator realizes greater yields and at the same time lower inverter costs. The Sunny Central MV is delivered as a "turnkey" concrete substation for outside installation. On top of that, the Sunny Central MV actively participates in grid management, and thereby fulfils all requirements of the Medium-Voltage Directive valid as of July 2010.

SUNNY CENTRAL 800MV / 1000MV / 1250MV

| Technical data | Sunny Central 800MV | Sunny Central 1000MV | Sunny Central 1250MV |
|---|-----------------------------|-----------------------------|-------------------------------|
| Input data | | | |
| Nominal DC power | 816 kW | 1018 kW | 1284 kW |
| Max. DC power | 900 kW ¹⁾ | 1120 kW ¹⁾ | 1410 kW ¹⁾ |
| MPP voltage range | 450 V - 820 V ⁵⁾ | 450 V - 820 V ⁵⁾ | 500 V - 820 V ⁵⁾⁷⁾ |
| Max. DC voltage | 1000 V | 1000 V | 1000 V |
| Max. DC current | 1986 A | 2484 A | 2844 A |
| Number of DC inputs | (16 + 16) + 4 DCHV | (16 + 16) + 4 DCHV | (16 + 16) + 4 DCHV |
| Output data | | | |
| Nominal AC power @ 45 °C | 800 kVA | 1000 kVA | 1250 kVA |
| Continuous AC power @ 25 °C | 880 kVA | 1100 kVA | 1400 kVA |
| Nominal AC voltage | 20000 V | 20000 V | 20000 V |
| Nominal AC current | 23.2 A | 28.8 A | 36.1 A |
| AC grid frequency 50 Hz | ● | ● | ● |
| AC grid frequency 60 Hz | ● | ● | ● |
| Power factor (cos φ) | 0.9 leading ... 0.9 lagging | | |
| Max. THD | < 3 % | < 3 % | < 3 % |
| Power consumption | | | |
| Internal consumption in operation | < 3000 W ⁴⁾ | < 3000 W ⁴⁾ | < 3000 W ⁴⁾ |
| Standby consumption | < 180 W + 1100 W | < 180 W + 1100 W | < 180 W + 1350 W |
| External auxiliary supply voltage | 3 x 230 V, 50/60 Hz | 3 x 230 V, 50/60 Hz | 3 x 230 V, 50/60 Hz |
| External back-up fuse for auxiliary supply | B 20 A, 3-pole | B 20 A, 3-pole | B 20 A, 3-pole |
| Dimensions and weight | | | |
| Height | 3620 mm | 3620 mm | 3620 mm |
| Width | 5400 mm | 5400 mm | 5400 mm |
| Depth | 3000 mm | 3000 mm | 3000 mm |
| Weight | 35000 kg | 35000 kg | 35000 kg |
| Efficiency²⁾ | | | |
| Max. efficiency | 97.7 % | 97.9 % | 97.8 % |
| Euro-eta | 97.3 % | 97.5 % | 97.4 % |
| Protection rating and ambient conditions | | | |
| Protection rating (as per EN 60529) | IP54 | IP54 | IP54 |
| Operating temperature range | -20 °C ... +45 °C | -20 °C ... +45 °C | -20 °C ... +45 °C |
| Rel. humidity | 15 % ... 95 % | 15 % ... 95 % | 15 % ... 95 % |
| Fresh air consumption | 12400 m ³ /h | 12400 m ³ /h | 12400 m ³ /h |
| Max. altitude (above sea level) | 1000 m | 1000 m | 1000 m |



| | Sunny Central 800MV | Sunny Central 1000MV | Sunny Central 1250MV |
|---|-----------------------------------|-----------------------------------|-----------------------------------|
| Features | | | |
| Display: text line / graphic | ●/– | ●/– | ●/– |
| Ground fault monitoring | ● | ● | ● |
| Heating | ● | ● | ● |
| Emergency stop | ● | ● | ● |
| Circuit breaker AC side | SI load disconnection switch | SI load disconnection switch | SI load disconnection switch |
| Circuit breaker DC side | Switch-disconnector with motor | Switch-disconnector with motor | Switch-disconnector with motor |
| Monitored overvoltage protectors AC / DC | ●/● | ●/● | ●/● |
| Monitored overvoltage protectors for auxiliary supply | ● | ● | ● |
| SCC (Sunny Central Control) interfaces | | | |
| Communication (NET Piggy-Back, optional) | analog, ISDN, Ethernet | analog, ISDN, Ethernet | analog, ISDN, Ethernet |
| Analog inputs | 10 x A _m ³⁾ | 10 x A _m ³⁾ | 10 x A _m ³⁾ |
| Overvoltage protection for analog inputs | ○ | ○ | ○ |
| Sunny String-Monitor connection (COM1) | RS485 | RS485 | RS485 |
| PC connection (COM3) | RS232 | RS232 | RS232 |
| Electrically separated relay (ext. alert signal) | 2 | 2 | 2 |
| Certificates / listings | | | |
| EMC | EN 61000-6-2 EN 61000-6-4 | | |
| CE conformity | ● | ● | ● |
| BDEW-MSRL / FGW / TR8 ⁶⁾ | ● | ● | ● |
| RD 1633 / 2000 | ● | ● | ● |
| Arrêté du 23/04/08 | ● | ● | ● |
| ● standard features ○ optional features – not available | | | |
| Type designation | SC 800MV-11 | SC 1000MV-11 | SC 1250MV-11 |

HE: High Efficiency, inverter without galvanic isolation for connection to a medium-voltage transformer (taking into account the SMA specification for the transformer)

1) Specifications apply to irradiation values below STC

2) Efficiency measured without an internal power supply at $U_{DC} = 500\text{ V}$

3) 2x inputs for the external nominal value specification for active power and reactive power, 1x external alarm input, 1x irradiation sensor, 1x pyranometer


4) Internal consumption at nominal power

5) At $1.05 U_{AC, nom}$ and $\cos \varphi = 1$


6) With limited dynamic grid support

7) At $f_{grid} = 60\text{ Hz}$: 510 V - 820 V

Please note: in certain countries the substations may differ from the substations shown in the images




POWERFUL GRID MANAGEMENT FUNCTIONS




Remote controlled power reduction in case of grid overload

In order to avoid short-term grid overload, the grid operator presets a nominal active power value which the inverter will implement within 60 seconds. The nominal value is transmitted to the inverters via a ripple control receiver in combination with the SMA Power Reducer Box. Typical limit values are 100, 60, 30 or 0 per cent of the nominal power.




Frequency-dependent control of active power

As of a grid frequency of 50.2 Hz, the inverter automatically reduces the fed-in of active power according to a definable characteristic curve which thereby contributes to the stabilization of the grid frequency.




Static voltage support based on reactive power

To stabilize the grid voltage, SMA inverters feed reactive power (leading or lagging) into the grid. Three different modes are available:




a) Fixed definition of the reactive power by the grid operator

The grid operator defines a fixed reactive power value or a fixed displacement factor between $\cos(\varphi)_{\text{leading}} = 0.90$ and $\cos(\varphi)_{\text{lagging}} = 0.90$.




b) Definition of a dynamic setpoint of the reactive power by the utility operator

The grid operator defines a dynamic displacement factor - any value between $\cos(\varphi)_{\text{leading}} = 0.90$ und $\cos(\varphi)_{\text{lagging}} = 0.90$. It is transmitted either through a communication unit the evaluation can e.g. be evaluated and processed by the SMA Power Reducer Box.



c) Control of the reactive power over a characteristic curve

The reactive power or the phase shift is controlled by a pre-defined characteristic curve - depending on the active power fed into the grid or the grid voltage.



Limited Dynamic Grid Support


The inverter continues to feed to the grid after short term voltage drops - as long as the grid voltage is within a defined voltage window.

SMA Solar Technologie Umrichteranlage Sunny Central SC 1000MV
 Betrieb bei Nennleistung und 50 Hz; 1000 KW

SMA Solar Technologies Inverter Unit Sunny Central SC 1000MV
 Name Plate Capacity 1000 kW at 50 Hz

A - bewerteter Schalleistungspegel LwA re 1 pW [dB(A)]

Evaluated sound power levels LwA ref 1pW [dBA]



Third octave band frequency [Hz]

Terz - Mittenfrequenz [Hz]

Estimated Frequency Spectra for Transformers

Transformer - 44kV/10MVA

From Handbook of Noise and Vibration Control (Crocker, 2007, page 1335-1336, Eq. 18 and Table 20) and Beranek's old notes (page 7-19)

Average LpA 68 dBA Based on NEMA TR1-1993 (R2000), Table 0-2
 Estimated surface area 35 m² Can be assumed, 25% of change will produce a difference of 1 dB on Lw, try to estimate on the high side

Correction factors are in dB

| Freq. (Hz) | 31 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | Notes |
|------------|-------|------|------|------|------|-------|-------|-------|-------|--|
| C1 | -11.0 | -5.0 | -3.0 | -8.0 | -8.0 | -14.0 | -19.0 | -24.0 | -31.0 | Outdoors, indoors in mechanical room over 140 m ³ |
| C2 | -11 | -2 | 3 | -2 | -2 | -11 | -19 | -24 | -31 | Indoors |
| C3 | -11 | -2 | 3 | 2 | 2 | -4 | -9 | -14 | -21 | Serious Noise Problems |

Sound Power Level calculated as $L_w = \text{Average LpA} + 10 \cdot \log(\text{Estimated surface area}) + C + 10$

| Freq. (Hz) | 31 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | Combined [dB] |
|---------------|------|------|------|------|------|------|------|------|------|---------------|
| C1 based [dB] | 82.4 | 88.4 | 90.4 | 85.4 | 85.4 | 79.4 | 74.4 | 69.4 | 62.4 | 94.5 |
| C2 based [dB] | 82.4 | 91.4 | 96.4 | 91.4 | 91.4 | 82.4 | 74.4 | 69.4 | 62.4 | 99.5 |
| C3 based [dB] | 82.4 | 91.4 | 96.4 | 95.4 | 95.4 | 89.4 | 84.4 | 79.4 | 72.4 | 101.5 |

Resulting A-weighted sound power level

| Freq. (Hz) | A-Weight | C1 based [dBA] | C2 based [dBA] | C2 based [dBA] |
|------------|----------|----------------|----------------|----------------|
| 31 | -39.4 | 43.0 | 52.0 | 57.0 |
| 63 | -26.2 | 62.2 | 65.2 | 65.2 |
| 125 | -16.1 | 74.3 | 80.3 | 80.3 |
| 250 | -8.6 | 76.8 | 82.8 | 86.8 |
| 500 | -3.2 | 82.2 | 88.2 | 92.2 |
| 1000 | 0 | 79.4 | 82.4 | 89.4 |
| 2000 | 1.2 | 75.6 | 75.6 | 85.6 |
| 4000 | 1 | 70.4 | 70.4 | 80.4 |
| 8000 | -1.1 | 61.3 | 61.3 | 71.3 |
| LwA [dBA] | | 85.8 | 90.8 | 95.6 |


 Used in the study

Figure B.1 Sound Power Level Calculation for 44-kV/10-MVA Substation Transformer.

| Third octave, as provided | | |
|---------------------------|-----------|-------------|
| Freq # | Freq (Hz) | LwA (dBA) |
| 1 | 25 | |
| 2 | 31.5 | |
| 3 | 40 | |
| 4 | 50 | 58.7 |
| 5 | 63 | 61.1 |
| 6 | 80 | 60.1 |
| 7 | 100 | 66.4 |
| 8 | 125 | 73.2 |
| 9 | 160 | 77.2 |
| 10 | 200 | 81.8 |
| 11 | 250 | 85.4 |
| 12 | 315 | 91.7 |
| 13 | 400 | 89.2 |
| 14 | 500 | 83.6 |
| 15 | 630 | 85.9 |
| 16 | 800 | 84.5 |
| 17 | 1000 | 85.7 |
| 18 | 1250 | 85.8 |
| 19 | 1600 | 83.4 |
| 20 | 2000 | 83.3 |
| 21 | 2500 | 81.7 |
| 22 | 3150 | 78.6 |
| 23 | 4000 | 72.9 |
| 24 | 5000 | 68.1 |
| 25 | 6300 | 65.4 |
| 26 | 8000 | |
| 27 | 10000 | |
| Total LwA | | 97.2 |

| Full octave, as used in CADNA-A model | | |
|---------------------------------------|-----------|-------------|
| Freq # | Freq (Hz) | LwA (dBA) |
| | 31.5 | |
| 5 | 63 | 64.8 |
| 8 | 125 | 78.9 |
| 11 | 250 | 93.0 |
| 14 | 500 | 91.6 |
| 17 | 1000 | 90.1 |
| 20 | 2000 | 87.6 |
| 23 | 4000 | 79.9 |
| 26 | 8000 | 65.4 |
| Total LwA | | 97.2 |

$$\rightarrow 10\log\left(10^{\frac{58.7}{10}} + 10^{\frac{61.1}{10}} + 10^{\frac{60.1}{10}}\right) = 64.8\text{dBA}$$




Figure B.2 Sound Power Level Calculation for SMA Sunny Central 1000MV, 100% LOAD.

Acoustical Louver J Blade

Application and Design



AFJ-601 is an acoustical weather louver designed to protect air intake and exhaust openings in building exterior walls. Design incorporates J style insulated acoustical blades and high free area to provide maximum resistance to sound transmission, rain and weather while providing minimum resistance to airflow. The AFJ-601 is an extremely efficient louver with **AMCA LICENSED PERFORMANCE DATA** enabling designers to select and apply with confidence.

Standard Construction

- Frame** Heavy gauge formed aluminum,
6 in. x 0.080 in. nominal wall thickness
- Blades** J style, heavy gauge formed aluminum,
0.080 in. nominal wall thickness, positioned
at 45° on approximately 5 in. centers
- Construction** . . . Mechanically fastened
- Acoustical
Insulation** Fiberglass Insulation
- Birdscreen** 3/4 in. x 0.051 flattened expanded aluminum in
removable frame, inside mount (rear)
- Finish** Mill
- Minimum Size** . . 12 in. W x 15 in. H
- Maximum Single
Section Size** . . . 60 in. W x 120 in. H

Options (at additional cost)

- A variety of bird and insect screens
- Blank off panels
- Clip angles
- Extended sill
- Filter racks
- Flanged frame
- Galvanized steel frame and blade
- Security bars
- A variety of architectural finishes including:
 - Clear anodize
 - Integral color anodize
 - Baked enamel paint
 - Kynar paint



*Width and height dimensions furnished approximately 1/4 inch under size.

PERFORMANCE DATA

AFJ-601

Free Area Chart (Sq. ft.)

**J Blade Acoustical Louver
Formed Aluminum**

| Louver Height Inches | Louver Width Inches | | | | | | | | |
|----------------------|---------------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| | 12 | 18 | 24 | 30 | 36 | 42 | 48 | 54 | 60 |
| 15 | 0.12 | 0.21 | 0.29 | 0.37 | 0.45 | 0.53 | 0.61 | 0.69 | 0.77 |
| 18 | 0.25 | 0.41 | 0.57 | 0.74 | 0.90 | 1.06 | 1.22 | 1.38 | 1.55 |
| 24 | 0.37 | 0.62 | 0.86 | 1.10 | 1.35 | 1.59 | 1.83 | 2.08 | 2.32 |
| 30 | 0.50 | 0.82 | 1.15 | 1.47 | 1.80 | 2.12 | 2.44 | 2.77 | 3.09 |
| 36 | 0.62 | 1.03 | 1.43 | 1.84 | 2.24 | 2.65 | 3.05 | 3.46 | 3.86 |
| 42 | 0.75 | 1.24 | 1.72 | 2.21 | 2.69 | 3.18 | 3.67 | 4.15 | 4.64 |
| 48 | 1.00 | 1.65 | 2.30 | 2.94 | 3.59 | 4.24 | 4.89 | 5.54 | 6.18 |
| 54 | 1.12 | 1.85 | 2.58 | 3.31 | 4.04 | 4.77 | 5.50 | 6.23 | 6.96 |
| 60 | 1.25 | 2.06 | 2.87 | 3.68 | 4.49 | 5.30 | 6.11 | 6.92 | 7.73 |
| 66 | 1.37 | 2.26 | 3.16 | 4.05 | 4.94 | 5.83 | 6.72 | 7.61 | 8.50 |
| 72 | 1.50 | 2.47 | 3.44 | 4.41 | 5.39 | 6.36 | 7.33 | 8.30 | 9.27 |
| 78 | 1.75 | 2.88 | 4.02 | 5.15 | 6.28 | 7.42 | 8.55 | 9.69 | 10.82 |
| 84 | 1.87 | 3.09 | 4.30 | 5.52 | 6.73 | 7.95 | 9.16 | 10.38 | 11.59 |
| 90 | 2.00 | 3.29 | 4.59 | 5.89 | 7.18 | 8.48 | 9.77 | 11.07 | 12.37 |
| 96 | 2.12 | 3.50 | 4.88 | 6.25 | 7.63 | 9.01 | 10.38 | 11.76 | 13.14 |
| 102 | 2.25 | 3.71 | 5.16 | 6.62 | 8.08 | 9.54 | 11.00 | 12.45 | 13.91 |
| 108 | 2.50 | 4.12 | 5.74 | 7.36 | 8.98 | 10.60 | 12.22 | 13.84 | 15.46 |
| 114 | 2.62 | 4.32 | 6.02 | 7.73 | 9.43 | 11.13 | 12.83 | 14.53 | 16.23 |
| 120 | 2.75 | 4.53 | 6.31 | 8.09 | 9.88 | 11.66 | 13.44 | 15.22 | 17.00 |



Greenheck Fan Corporation certifies that the AFJ-601 louvers shown herein are licensed to bear the AMCA Seal. The ratings shown are based on tests and procedures performed in accordance with AMCA Publication 511 and comply with the requirements of the AMCA Certified Ratings Program. The AMCA Certified Ratings Seal applies to water penetration, air performance and sound ratings.

Sound Transmission Class

The Sound Transmission Class (STC) is a rating of the effectiveness of an assembly in isolating or reducing airborne sound transmission. STC is a single number that summarizes airborne sound transmission loss data. Assemblies with higher STC ratings are more efficient at reducing sound transmission. STC is determined in accordance with ASTM E413-04.

Transmission Loss


Transmission loss (TL) is a measurement of the reduction of sound power transmission (dB) through an assembly at a given frequency. The more sound power that is reduced, the greater the TL. TL is tested in accordance with ASTM E90-04.

Free Field Noise Reduction in Decibels

Free Field Noise Reduction is determined by adding 6 dB to the Transmission Loss.

| Octave Band | 2 | 3 | 4 | 5 | 6 | 7 | STC |
|---------------------------------|----|-----|-----|-----|------|------|-----|
| Frequency (Hz) | 63 | 125 | 250 | 500 | 1000 | 2000 | 10 |
| Transmission Loss (dB) | 4 | 4 | 6 | 10 | 17 | 12 | |
| Free Field Noise Reduction (dB) | 10 | 10 | 12 | 16 | 23 | 18 | |


Airflow Resistance (Standard Air - .075 lb/ft³)



Model AFJ-601 resistance to airflow (pressure drop) varies depending on louver application (air intake or air exhaust). Free area velocities (shown) are higher than average velocity through the overall louver size. See louver selection information.

Water Penetration (Standard Air - .075 lb/ft³)

Test size 48 in. x 48 in. Test duration of 15 min.



The AMCA Water Penetration Test provides a method for comparing various louver models and designs as to their efficiency in resisting the penetration of rainfall under specific laboratory test conditions. The beginning point of water penetration is defined as that velocity where the water penetration curve projects through .01 oz. of water (penetration) per sq. ft. of louver free area.

***The beginning point of water penetration for Model AFJ-601 is 799 fpm free area velocity.** These performance ratings do not guarantee a louver to be weatherproof or stormproof and should be used in combination with other factors including good engineering judgement in selecting louvers.




INSTALLATION DETAILS

AFJ-601

Maximum Size and Installation Information

J Blade Acoustical Louver
Formed Aluminum

Maximum single section size for model AFJ-601 is 60 in. W x 120 in. H. Larger openings require field assembly of multiple louver panels to make up the overall opening size. Individual louver panels are designed to withstand a 25 PSF wind-load (please consult Greenheck if the louvers must withstand higher wind-loads). Structural reinforcing members may be required to adequately support and install multiple louver panels within a large opening. Structural reinforcing members along with any associated installation hardware is not provided by Greenheck unless indicated otherwise by Greenheck. Additional information on louver installation may be found in AMCA Publication #501, Louver Application Manual.




Minimum Single Section Size
12 in. W x 15 in. H


Maximum Single Section Size
60 in. W x 120 in. H

PRODUCT DETAILS

AFJ-601

J Blade Acoustical Louver
Formed Aluminum





FINISHES

| Finish Type | Description/Application | Color Selection | Standard Warranty (Aluminum) |
|---|--|---|---|
| 2-coat 70% KYNAR 500®/HYLAR 5000® AAMA 2605 – Dry film thickness 1.2 mil. (AKA: Duranar®, Fluoropon®, Trinar®, Flouropolymer, Polyvinylidene Fluoride, PVDF2) | “Best.” The premier finish for extruded aluminum. Tough, long-lasting coating has superior color retention and abrasive properties. Resists chalking, fading, chemical abrasion and weathering. | Standard Colors: Any of the 24 standard colors shown can be furnished in 70% or 50% KYNAR 500®/HYLAR 5000® or Baked Enamel. 2-Coat Mica: Greenheck offers 9 standard 2-coat Mica colors. Other colors are available. Consult Greenheck for possible extra cost when selecting non-standard colors or special finishes. | 10 Years (Consult Greenheck for availability of extended warranty) |
| 2-coat 50% KYNAR 500®/HYLAR 5000® AAMA 2604 – Dry film thickness 1.2 mil. (AKA: Acroflur®, Acrynar®) | “Better.” Tough, long-lasting coating has excellent color retention and abrasive properties. Resists chalking, fading, chemical abrasion and weathering. | | 5 Years |
| Baked Enamel AAMA 2603 – Dry film thickness 0.8 mil. (AKA: Acrabond Plus®, Duracron®) | “Good.” Provides good adhesion and resistance to weathering, corrosion and chemical stain. | | 1 Year |
| Integral Color Anodize AA-M10C22A42 (>0.7 mil) | “Two-step” anodizing is produced by following the normal anodizing step with a second, colorfast process. | Light, Medium or Dark Bronze; Champagne; Black | 5 years |
| Clear Anodize 215 R-1 AA-M10C22A41 (>0.7 mil) | Clear, colorless and hard oxide aluminum coating that resists weathering and chemical attack. | Clear | 5 years |
| Clear Anodize 204 R-1 AA-M10C22A31 (0.4-0.7 mil) | Clear, colorless and hard oxide aluminum coating that resists weathering and chemical attack. | Clear | 1 Year |
| Industrial coatings | Greenheck offers a number of industrial coatings such as Hi-Pro Polyester, Epoxy, and Permatector®. Consult a Greenheck Product Specialist for complete color and application information. | | Consult Greenheck |
| Mill | Materials may be supplied in natural aluminum or galvanized steel finish when normal weathering is acceptable and there is no concern for color or color change. | | n/a |




Finishes meet or exceed AAMA 2605, AAMA 2604, and AAMA 2603 requirements. Please consult www.greenheck.com for complete information on standard and extended paint warranties. Paint finish warranties are not applicable to steel products.



STANDARD FEATURES

STANDARD FEATURES

1. L.V. BUSHING
2. H.V. BUSHING
3. TANK WITH WELDED-ON COVER
4. HANDHOLE
5. COOLING PANELS
6. GAS SAMPLING VALVE
7. PRESSURE VACUUM GAUGE
8. PRESSURE RELIEF VALVE
9. 1" FILL PLUG AND FILTER PRESS CONNECTION
10. STAINLESS STEEL NAMEPLATE AND CONNECTION DIAGRAM
11. LIQUID LEVEL GAUGE
12. DIAL-TYPE THERMOMETER
13. DE-ENERGIZED TAPCHANGER
14. 1" DRAIN VALVE WITH 3/8" SAMPLING DEVICE
15. BASE SUITABLE FOR JACKING, SKIDDING, OR ROLLING
16. NEMA GROUND PAD





| KVA | Fluid | Cond | HV BIL | LV BIL | WD | LG | A | B | C | D | E | F | Gal Liquid | Weight |
|-------|-------|------|--------|--------|----|----|-----|-----|-----|-----|-----|----|---------------|--------|
| 10000 | O | C | 250 | 150 | 48 | 95 | 111 | 113 | 138 | TBD | 132 | 82 | 1530 | 37597 |

Figure B.3 Catalogue Dimensions (inches) of Substation Transformer, Obtained from Magna Electric Corporation.


Appendix C

Noise Map from CADNA-A



Legend

- PR## Parcel Identifier
- ✚ Inv# Inverter Unit
- ✚ Sub Substation Transformer
- ✚ # Noise Receptor
- # Representative Noise Receptor
- +— Railway
- Road
- Watercourse
- ▭ Parcel
- ▭ Parrott's Bay Conservation Area
- - - Project Site
- ▭ Wooded Area



Notes:
 1. OBM and NRVIS data downloaded from LIO with permission.
 2. Spatial referencing UTM NAD 83.

Figure C.1
 Axiom Power Canada Inc./SunEdison Canada
 Napanee TS Taylor Kidd Solar Project
Noise Contours at 4.5 m



Appendix D

CADNA-A Sample Calculations

| Configuration | |
|--|--------------------------------|
| Parameter | Value |
| General | |
| Country | (user defined) |
| Max. Error (dB) | 0.00 |
| Max. Search Radius (m) | 3000.00 |
| Min. Dist Src to Rcvr | 0.00 |
| Partition | |
| Raster Factor | 0.50 |
| Max. Length of Section (m) | 1000.00 |
| Min. Length of Section (m) | 1.00 |
| Min. Length of Section (%) | 0.00 |
| Proj. Line Sources | On |
| Proj. Area Sources | On |
| Ref. Time | |
| Reference Time Day (min) | 960.00 |
| Reference Time Night (min) | 480.00 |
| Daytime Penalty (dB) | 0.00 |
| Recr. Time Penalty (dB) | 0.00 |
| Night-time Penalty (dB) | 0.00 |
| DTM | |
| Standard Height (m) | 0.00 |
| Model of Terrain | Triangulation |
| Reflection | |
| max. Order of Reflection | 1 |
| Search Radius Src | 100.00 |
| Search Radius Rcvr | 100.00 |
| Max. Distance Source - Rcvr | 1000.00 1000.00 |
| Min. Distance Rcvr - Reflector | 1.00 1.00 |
| Min. Distance Source - Reflector | 0.10 |
| Industrial (ISO 9613) | |
| Lateral Diffraction | some Obj |
| Obst. within Area Src do not shield | On |
| Screening | |
| | Excl. Ground Att. over Barrier |
| | Dz with limit (20/25) |
| Barrier Coefficients C1,2,3 | 3.0 20.0 0.0 |
| Temperature (°C) | 10 |
| rel. Humidity (%) | 70 |
| Ground Absorption G | 0.70 |
| Wind Speed for Dir. (m/s) | 3.0 |
| Roads (RLS-90) | |
| Strictly acc. to RLS-90 | |
| Railways (Schall 03) | |
| Strictly acc. to Schall 03 / Schall-Transrapid | |
| Aircraft (???) | |
| Strictly acc. to AzB | |

Receiver

Name: Receptors - Existing

ID: 1.0

X: 363386.33

Y: 4897369.40

Z: 4.50

Point Source, ISO 9613, Name: "Sub", ID: "Sub"

| Nr. | X (m) | Y (m) | Z (m) | Refl. | Freq. (Hz) | LxT dB(A) | LxN dB(A) | K0 (dB) | Dc (dB) | Adiv (dB) | Aatm (dB) | Agr (dB) | Afol (dB) | Ahous (dB) | Abar (dB) | Cmet (dB) | RL (dB) | LrT dB(A) | LrN dB(A) |
|-----|-----------|------------|----------|-------|---------------|--------------|--------------|------------|------------|--------------|--------------|-------------|--------------|---------------|--------------|--------------|------------|--------------|--------------|
| 1 | 363659.65 | 4897474.55 | 3.00 | 0 | 32 | 48.0 | 48.0 | 0.0 | 0.0 | 60.3 | 0.0 | -3.7 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | -8.7 | -8.7 |
| 2 | 363659.65 | 4897474.55 | 3.00 | 0 | 63 | 67.2 | 67.2 | 0.0 | 0.0 | 60.3 | 0.0 | -3.7 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 10.5 | 10.5 |
| 3 | 363659.65 | 4897474.55 | 3.00 | 0 | 125 | 79.3 | 79.3 | 0.0 | 0.0 | 60.3 | 0.1 | 2.7 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 16.1 | 16.1 |
| 4 | 363659.65 | 4897474.55 | 3.00 | 0 | 250 | 81.8 | 81.8 | 0.0 | 0.0 | 60.3 | 0.3 | 2.5 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 18.6 | 18.6 |
| 5 | 363659.65 | 4897474.55 | 3.00 | 0 | 500 | 87.2 | 87.2 | 0.0 | 0.0 | 60.3 | 0.6 | -1.0 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 27.3 | 27.3 |
| 6 | 363659.65 | 4897474.55 | 3.00 | 0 | 1000 | 84.4 | 84.4 | 0.0 | 0.0 | 60.3 | 1.1 | -1.1 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 24.1 | 24.1 |
| 7 | 363659.65 | 4897474.55 | 3.00 | 0 | 2000 | 80.6 | 80.6 | 0.0 | 0.0 | 60.3 | 2.8 | -1.1 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 18.6 | 18.6 |
| 8 | 363659.65 | 4897474.55 | 3.00 | 0 | 4000 | 75.4 | 75.4 | 0.0 | 0.0 | 60.3 | 9.6 | -1.1 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 6.6 | 6.6 |
| 9 | 363659.65 | 4897474.55 | 3.00 | 0 | 8000 | 66.3 | 66.3 | 0.0 | 0.0 | 60.3 | 34.2 | -1.1 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | -27.2 | -27.2 |

Point Source, ISO 9613, Name: "Inv01", ID: "Inv01"

| Nr. | X (m) | Y (m) | Z (m) | Refl. | Freq. (Hz) | LxT dB(A) | LxN dB(A) | K0 (dB) | Dc (dB) | Adiv (dB) | Aatm (dB) | Agr (dB) | Afol (dB) | Ahous (dB) | Abar (dB) | Cmet (dB) | RL (dB) | LrT dB(A) | LrN dB(A) |
|-----|-----------|------------|----------|-------|---------------|--------------|--------------|------------|------------|--------------|--------------|-------------|--------------|---------------|--------------|--------------|------------|--------------|--------------|
| 1 | 363311.65 | 4897948.61 | 3.50 | 0 | 63 | 59.8 | 59.8 | 0.0 | 0.0 | 66.3 | 0.1 | -4.8 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | -1.8 | -1.8 |
| 2 | 363311.65 | 4897948.61 | 3.50 | 0 | 125 | 73.9 | 73.9 | 0.0 | 0.0 | 66.3 | 0.2 | 3.4 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 3.9 | 3.9 |
| 3 | 363311.65 | 4897948.61 | 3.50 | 0 | 250 | 86.0 | 86.0 | 0.0 | 0.0 | 66.3 | 0.6 | 1.5 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 17.5 | 17.5 |
| 4 | 363311.65 | 4897948.61 | 3.50 | 0 | 500 | 80.6 | 80.6 | 0.0 | 0.0 | 66.3 | 1.1 | -1.4 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 14.5 | 14.5 |
| 5 | 363311.65 | 4897948.61 | 3.50 | 0 | 1000 | 72.1 | 72.1 | 0.0 | 0.0 | 66.3 | 2.1 | -1.4 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 5.1 | 5.1 |
| 6 | 363311.65 | 4897948.61 | 3.50 | 0 | 2000 | 74.6 | 74.6 | 0.0 | 0.0 | 66.3 | 5.6 | -1.4 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 4.1 | 4.1 |
| 7 | 363311.65 | 4897948.61 | 3.50 | 0 | 4000 | 84.9 | 84.9 | 0.0 | 0.0 | 66.3 | 19.1 | -1.4 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 0.9 | 0.9 |
| 8 | 363311.65 | 4897948.61 | 3.50 | 0 | 8000 | 70.4 | 70.4 | 0.0 | 0.0 | 66.3 | 68.3 | -1.4 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | -62.8 | -62.8 |

Point Source, ISO 9613, Name: "Inv02", ID: "Inv02"

| Nr. | X (m) | Y (m) | Z (m) | Refl. | Freq. (Hz) | LxT dB(A) | LxN dB(A) | K0 (dB) | Dc (dB) | Adiv (dB) | Aatm (dB) | Agr (dB) | Afol (dB) | Ahous (dB) | Abar (dB) | Cmet (dB) | RL (dB) | LrT dB(A) | LrN dB(A) |
|-----|-----------|------------|----------|-------|---------------|--------------|--------------|------------|------------|--------------|--------------|-------------|--------------|---------------|--------------|--------------|------------|--------------|--------------|
| 1 | 363347.45 | 4897858.37 | 3.50 | 0 | 63 | 59.8 | 59.8 | 0.0 | 0.0 | 64.8 | 0.1 | -4.5 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | -0.5 | -0.5 |
| 2 | 363347.45 | 4897858.37 | 3.50 | 0 | 125 | 73.9 | 73.9 | 0.0 | 0.0 | 64.8 | 0.2 | 3.3 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 5.6 | 5.6 |
| 3 | 363347.45 | 4897858.37 | 3.50 | 0 | 250 | 86.0 | 86.0 | 0.0 | 0.0 | 64.8 | 0.5 | 1.6 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 19.1 | 19.1 |
| 4 | 363347.45 | 4897858.37 | 3.50 | 0 | 500 | 80.6 | 80.6 | 0.0 | 0.0 | 64.8 | 1.0 | -1.3 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 16.2 | 16.2 |
| 5 | 363347.45 | 4897858.37 | 3.50 | 0 | 1000 | 72.1 | 72.1 | 0.0 | 0.0 | 64.8 | 1.8 | -1.4 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 6.8 | 6.8 |
| 6 | 363347.45 | 4897858.37 | 3.50 | 0 | 2000 | 74.6 | 74.6 | 0.0 | 0.0 | 64.8 | 4.7 | -1.4 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 6.4 | 6.4 |
| 7 | 363347.45 | 4897858.37 | 3.50 | 0 | 4000 | 84.9 | 84.9 | 0.0 | 0.0 | 64.8 | 16.1 | -1.4 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 5.4 | 5.4 |
| 8 | 363347.45 | 4897858.37 | 3.50 | 0 | 8000 | 70.4 | 70.4 | 0.0 | 0.0 | 64.8 | 57.3 | -1.4 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | -50.4 | -50.4 |

Point Source, ISO 9613, Name: "Inv03", ID: "Inv03"

| Nr. | X (m) | Y (m) | Z (m) | Refl. | Freq. (Hz) | LxT dB(A) | LxN dB(A) | K0 (dB) | Dc (dB) | Adiv (dB) | Aatm (dB) | Agr (dB) | Afol (dB) | Ahous (dB) | Abar (dB) | Cmet (dB) | RL (dB) | LrT dB(A) | LrN dB(A) |
|-----|-----------|------------|----------|-------|---------------|--------------|--------------|------------|------------|--------------|--------------|-------------|--------------|---------------|--------------|--------------|------------|--------------|--------------|
| 1 | 363381.49 | 4897778.47 | 3.50 | 0 | 63 | 59.8 | 59.8 | 0.0 | 0.0 | 63.2 | 0.1 | -4.2 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 0.8 | 0.8 |
| 2 | 363381.49 | 4897778.47 | 3.50 | 0 | 125 | 73.9 | 73.9 | 0.0 | 0.0 | 63.2 | 0.2 | 3.1 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 7.4 | 7.4 |
| 3 | 363381.49 | 4897778.47 | 3.50 | 0 | 250 | 86.0 | 86.0 | 0.0 | 0.0 | 63.2 | 0.4 | 1.7 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 20.6 | 20.6 |
| 4 | 363381.49 | 4897778.47 | 3.50 | 0 | 500 | 80.6 | 80.6 | 0.0 | 0.0 | 63.2 | 0.8 | -1.2 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 17.8 | 17.8 |
| 5 | 363381.49 | 4897778.47 | 3.50 | 0 | 1000 | 72.1 | 72.1 | 0.0 | 0.0 | 63.2 | 1.5 | -1.3 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 8.6 | 8.6 |
| 6 | 363381.49 | 4897778.47 | 3.50 | 0 | 2000 | 74.6 | 74.6 | 0.0 | 0.0 | 63.2 | 3.9 | -1.3 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 8.7 | 8.7 |
| 7 | 363381.49 | 4897778.47 | 3.50 | 0 | 4000 | 84.9 | 84.9 | 0.0 | 0.0 | 63.2 | 13.4 | -1.3 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 9.5 | 9.5 |
| 8 | 363381.49 | 4897778.47 | 3.50 | 0 | 8000 | 70.4 | 70.4 | 0.0 | 0.0 | 63.2 | 47.8 | -1.3 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | -39.4 | -39.4 |

Point Source, ISO 9613, Name: "Inv04", ID: "Inv04"

| Nr. | X (m) | Y (m) | Z (m) | Refl. | Freq. (Hz) | LxT dB(A) | LxN dB(A) | K0 (dB) | Dc (dB) | Adiv (dB) | Aatm (dB) | Agr (dB) | Afol (dB) | Ahous (dB) | Abar (dB) | Cmet (dB) | RL (dB) | LrT dB(A) | LrN dB(A) |
|-----|-----------|------------|----------|-------|---------------|--------------|--------------|------------|------------|--------------|--------------|-------------|--------------|---------------|--------------|--------------|------------|--------------|--------------|
| 1 | 363425.85 | 4897677.52 | 3.50 | 0 | 63 | 59.8 | 59.8 | 0.0 | 0.0 | 60.8 | 0.0 | -3.7 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 2.6 | 2.6 |
| 2 | 363425.85 | 4897677.52 | 3.50 | 0 | 125 | 73.9 | 73.9 | 0.0 | 0.0 | 60.8 | 0.1 | 3.0 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 9.9 | 9.9 |
| 3 | 363425.85 | 4897677.52 | 3.50 | 0 | 250 | 86.0 | 86.0 | 0.0 | 0.0 | 60.8 | 0.3 | 1.9 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 23.0 | 23.0 |
| 4 | 363425.85 | 4897677.52 | 3.50 | 0 | 500 | 80.6 | 80.6 | 0.0 | 0.0 | 60.8 | 0.6 | -1.1 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 20.2 | 20.2 |

| Point Source, ISO 9613, Name: "Inv04", ID: "Inv04" | | | | | | | | | | | | | | | | | | | |
|--|-----------|------------|------|-------|-------|-------|-------|------|------|------|------|------|------|-------|------|------|------|-------|-------|
| Nr. | X | Y | Z | Refl. | Freq. | LxT | LxN | K0 | Dc | Adiv | Aatm | Agr | Afol | Ahous | Abar | Cmet | RL | LrT | LrN |
| | (m) | (m) | (m) | | (Hz) | dB(A) | dB(A) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | dB(A) | dB(A) |
| 5 | 363425.85 | 4897677.52 | 3.50 | 0 | 1000 | 72.1 | 72.1 | 0.0 | 0.0 | 60.8 | 1.1 | -1.1 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 11.2 | 11.2 |
| 6 | 363425.85 | 4897677.52 | 3.50 | 0 | 2000 | 74.6 | 74.6 | 0.0 | 0.0 | 60.8 | 3.0 | -1.1 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 11.9 | 11.9 |
| 7 | 363425.85 | 4897677.52 | 3.50 | 0 | 4000 | 84.9 | 84.9 | 0.0 | 0.0 | 60.8 | 10.2 | -1.1 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 15.0 | 15.0 |
| 8 | 363425.85 | 4897677.52 | 3.50 | 0 | 8000 | 70.4 | 70.4 | 0.0 | 0.0 | 60.8 | 36.3 | -1.1 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | -25.7 | -25.7 |

| Point Source, ISO 9613, Name: "Inv05", ID: "Inv05" | | | | | | | | | | | | | | | | | | | |
|--|-----------|------------|------|-------|-------|-------|-------|------|------|------|------|------|------|-------|------|------|------|-------|-------|
| Nr. | X | Y | Z | Refl. | Freq. | LxT | LxN | K0 | Dc | Adiv | Aatm | Agr | Afol | Ahous | Abar | Cmet | RL | LrT | LrN |
| | (m) | (m) | (m) | | (Hz) | dB(A) | dB(A) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | dB(A) | dB(A) |
| 1 | 363458.72 | 4897597.41 | 3.50 | 0 | 63 | 59.8 | 59.8 | 0.0 | 0.0 | 58.6 | 0.0 | -3.0 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 4.2 | 4.2 |
| 2 | 363458.72 | 4897597.41 | 3.50 | 0 | 125 | 73.9 | 73.9 | 0.0 | 0.0 | 58.6 | 0.1 | 3.0 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 12.2 | 12.2 |
| 3 | 363458.72 | 4897597.41 | 3.50 | 0 | 250 | 86.0 | 86.0 | 0.0 | 0.0 | 58.6 | 0.3 | 2.0 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 25.1 | 25.1 |
| 4 | 363458.72 | 4897597.41 | 3.50 | 0 | 500 | 80.6 | 80.6 | 0.0 | 0.0 | 58.6 | 0.5 | -0.9 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 22.4 | 22.4 |
| 5 | 363458.72 | 4897597.41 | 3.50 | 0 | 1000 | 72.1 | 72.1 | 0.0 | 0.0 | 58.6 | 0.9 | -0.9 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 13.6 | 13.6 |
| 6 | 363458.72 | 4897597.41 | 3.50 | 0 | 2000 | 74.6 | 74.6 | 0.0 | 0.0 | 58.6 | 2.3 | -0.9 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 14.6 | 14.6 |
| 7 | 363458.72 | 4897597.41 | 3.50 | 0 | 4000 | 84.9 | 84.9 | 0.0 | 0.0 | 58.6 | 7.8 | -0.9 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 19.4 | 19.4 |
| 8 | 363458.72 | 4897597.41 | 3.50 | 0 | 8000 | 70.4 | 70.4 | 0.0 | 0.0 | 58.6 | 28.0 | -0.9 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | -15.2 | -15.2 |

| Point Source, ISO 9613, Name: "Inv06", ID: "Inv06" | | | | | | | | | | | | | | | | | | | |
|--|-----------|------------|------|-------|-------|-------|-------|------|------|------|------|------|------|-------|------|------|------|-------|-------|
| Nr. | X | Y | Z | Refl. | Freq. | LxT | LxN | K0 | Dc | Adiv | Aatm | Agr | Afol | Ahous | Abar | Cmet | RL | LrT | LrN |
| | (m) | (m) | (m) | | (Hz) | dB(A) | dB(A) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | dB(A) | dB(A) |
| 1 | 363596.04 | 4897948.71 | 3.50 | 0 | 63 | 59.8 | 59.8 | 0.0 | 0.0 | 66.8 | 0.1 | -4.8 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | -2.2 | -2.2 |
| 2 | 363596.04 | 4897948.71 | 3.50 | 0 | 125 | 73.9 | 73.9 | 0.0 | 0.0 | 66.8 | 0.3 | 3.5 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 3.4 | 3.4 |
| 3 | 363596.04 | 4897948.71 | 3.50 | 0 | 250 | 86.0 | 86.0 | 0.0 | 0.0 | 66.8 | 0.6 | 1.5 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 17.0 | 17.0 |
| 4 | 363596.04 | 4897948.71 | 3.50 | 0 | 500 | 80.6 | 80.6 | 0.0 | 0.0 | 66.8 | 1.2 | -1.4 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 14.0 | 14.0 |
| 5 | 363596.04 | 4897948.71 | 3.50 | 0 | 1000 | 72.1 | 72.1 | 0.0 | 0.0 | 66.8 | 2.3 | -1.5 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 4.5 | 4.5 |
| 6 | 363596.04 | 4897948.71 | 3.50 | 0 | 2000 | 74.6 | 74.6 | 0.0 | 0.0 | 66.8 | 6.0 | -1.5 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 3.3 | 3.3 |
| 7 | 363596.04 | 4897948.71 | 3.50 | 0 | 4000 | 84.9 | 84.9 | 0.0 | 0.0 | 66.8 | 20.2 | -1.5 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | -0.6 | -0.6 |
| 8 | 363596.04 | 4897948.71 | 3.50 | 0 | 8000 | 70.4 | 70.4 | 0.0 | 0.0 | 66.8 | 72.0 | -1.5 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | -67.0 | -67.0 |

| Point Source, ISO 9613, Name: "Inv07", ID: "Inv07" | | | | | | | | | | | | | | | | | | | |
|--|-----------|------------|------|-------|-------|-------|-------|------|------|------|------|------|------|-------|------|------|------|-------|-------|
| Nr. | X | Y | Z | Refl. | Freq. | LxT | LxN | K0 | Dc | Adiv | Aatm | Agr | Afol | Ahous | Abar | Cmet | RL | LrT | LrN |
| | (m) | (m) | (m) | | (Hz) | dB(A) | dB(A) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | dB(A) | dB(A) |
| 1 | 363635.77 | 4897858.27 | 3.50 | 0 | 63 | 59.8 | 59.8 | 0.0 | 0.0 | 65.8 | 0.1 | -4.7 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | -1.4 | -1.4 |
| 2 | 363635.77 | 4897858.27 | 3.50 | 0 | 125 | 73.9 | 73.9 | 0.0 | 0.0 | 65.8 | 0.2 | 3.4 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 4.5 | 4.5 |
| 3 | 363635.77 | 4897858.27 | 3.50 | 0 | 250 | 86.0 | 86.0 | 0.0 | 0.0 | 65.8 | 0.6 | 1.6 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 18.1 | 18.1 |
| 4 | 363635.77 | 4897858.27 | 3.50 | 0 | 500 | 80.6 | 80.6 | 0.0 | 0.0 | 65.8 | 1.1 | -1.4 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 15.1 | 15.1 |
| 5 | 363635.77 | 4897858.27 | 3.50 | 0 | 1000 | 72.1 | 72.1 | 0.0 | 0.0 | 65.8 | 2.0 | -1.4 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 5.7 | 5.7 |
| 6 | 363635.77 | 4897858.27 | 3.50 | 0 | 2000 | 74.6 | 74.6 | 0.0 | 0.0 | 65.8 | 5.3 | -1.4 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 4.9 | 4.9 |
| 7 | 363635.77 | 4897858.27 | 3.50 | 0 | 4000 | 84.9 | 84.9 | 0.0 | 0.0 | 65.8 | 18.0 | -1.4 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 2.5 | 2.5 |
| 8 | 363635.77 | 4897858.27 | 3.50 | 0 | 8000 | 70.4 | 70.4 | 0.0 | 0.0 | 65.8 | 64.1 | -1.4 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | -58.1 | -58.1 |

| Point Source, ISO 9613, Name: "Inv08", ID: "Inv08" | | | | | | | | | | | | | | | | | | | |
|--|-----------|------------|------|-------|-------|-------|-------|------|------|------|------|------|------|-------|------|------|------|-------|-------|
| Nr. | X | Y | Z | Refl. | Freq. | LxT | LxN | K0 | Dc | Adiv | Aatm | Agr | Afol | Ahous | Abar | Cmet | RL | LrT | LrN |
| | (m) | (m) | (m) | | (Hz) | dB(A) | dB(A) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | dB(A) | dB(A) |
| 1 | 363670.99 | 4897778.16 | 3.50 | 0 | 63 | 59.8 | 59.8 | 0.0 | 0.0 | 65.0 | 0.1 | -4.5 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | -0.7 | -0.7 |
| 2 | 363670.99 | 4897778.16 | 3.50 | 0 | 125 | 73.9 | 73.9 | 0.0 | 0.0 | 65.0 | 0.2 | 3.3 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 5.5 | 5.5 |
| 3 | 363670.99 | 4897778.16 | 3.50 | 0 | 250 | 86.0 | 86.0 | 0.0 | 0.0 | 65.0 | 0.5 | 1.6 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 18.9 | 18.9 |
| 4 | 363670.99 | 4897778.16 | 3.50 | 0 | 500 | 80.6 | 80.6 | 0.0 | 0.0 | 65.0 | 1.0 | -1.3 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 16.0 | 16.0 |
| 5 | 363670.99 | 4897778.16 | 3.50 | 0 | 1000 | 72.1 | 72.1 | 0.0 | 0.0 | 65.0 | 1.8 | -1.4 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 6.7 | 6.7 |
| 6 | 363670.99 | 4897778.16 | 3.50 | 0 | 2000 | 74.6 | 74.6 | 0.0 | 0.0 | 65.0 | 4.8 | -1.4 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 6.2 | 6.2 |
| 7 | 363670.99 | 4897778.16 | 3.50 | 0 | 4000 | 84.9 | 84.9 | 0.0 | 0.0 | 65.0 | 16.3 | -1.4 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 5.0 | 5.0 |
| 8 | 363670.99 | 4897778.16 | 3.50 | 0 | 8000 | 70.4 | 70.4 | 0.0 | 0.0 | 65.0 | 58.2 | -1.4 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | -51.4 | -51.4 |

| Point Source, ISO 9613, Name: "Inv09", ID: "Inv09" | | | | | | | | | | | | | | | | | | | |
|--|-----------|------------|------|-------|-------|-------|-------|------|------|------|------|------|------|-------|------|------|------|-------|-------|
| Nr. | X | Y | Z | Refl. | Freq. | LxT | LxN | K0 | Dc | Adiv | Aatm | Agr | Afol | Ahous | Abar | Cmet | RL | LrT | LrN |
| | (m) | (m) | (m) | | (Hz) | dB(A) | dB(A) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | dB(A) | dB(A) |
| 1 | 363710.92 | 4897687.56 | 3.50 | 0 | 63 | 59.8 | 59.8 | 0.0 | 0.0 | 64.1 | 0.1 | -4.4 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 0.0 | 0.0 |
| 2 | 363710.92 | 4897687.56 | 3.50 | 0 | 125 | 73.9 | 73.9 | 0.0 | 0.0 | 64.1 | 0.2 | 3.2 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 6.4 | 6.4 |
| 3 | 363710.92 | 4897687.56 | 3.50 | 0 | 250 | 86.0 | 86.0 | 0.0 | 0.0 | 64.1 | 0.5 | 1.7 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 19.7 | 19.7 |
| 4 | 363710.92 | 4897687.56 | 3.50 | 0 | 500 | 80.6 | 80.6 | 0.0 | 0.0 | 64.1 | 0.9 | -1.3 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 16.9 | 16.9 |
| 5 | 363710.92 | 4897687.56 | 3.50 | 0 | 1000 | 72.1 | 72.1 | 0.0 | 0.0 | 64.1 | 1.7 | -1.3 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 7.6 | 7.6 |
| 6 | 363710.92 | 4897687.56 | 3.50 | 0 | 2000 | 74.6 | 74.6 | 0.0 | 0.0 | 64.1 | 4.4 | -1.3 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 7.4 | 7.4 |
| 7 | 363710.92 | 4897687.56 | 3.50 | 0 | 4000 | 84.9 | 84.9 | 0.0 | 0.0 | 64.1 | 14.9 | -1.3 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 7.2 | 7.2 |

| Point Source, ISO 9613, Name: "Inv09", ID: "Inv09" | | | | | | | | | | | | | | | | | | | |
|--|-----------|------------|------|-------|-------|-------|-------|------|------|------|------|------|------|-------|------|------|------|-------|-------|
| Nr. | X | Y | Z | Refl. | Freq. | LxT | LxN | K0 | Dc | Adiv | Aatm | Agr | Afol | Ahous | Abar | Cmet | RL | LrT | LrN |
| | (m) | (m) | (m) | | (Hz) | dB(A) | dB(A) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | dB(A) | dB(A) |
| 8 | 363710.92 | 4897687.56 | 3.50 | 0 | 8000 | 70.4 | 70.4 | 0.0 | 0.0 | 64.1 | 53.1 | -1.3 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | -45.5 | -45.5 |

| Point Source, ISO 9613, Name: "Inv10", ID: "Inv10" | | | | | | | | | | | | | | | | | | | |
|--|-----------|------------|------|-------|-------|-------|-------|------|------|------|------|------|------|-------|------|------|------|-------|-------|
| Nr. | X | Y | Z | Refl. | Freq. | LxT | LxN | K0 | Dc | Adiv | Aatm | Agr | Afol | Ahous | Abar | Cmet | RL | LrT | LrN |
| | (m) | (m) | (m) | | (Hz) | dB(A) | dB(A) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | (dB) | dB(A) | dB(A) |
| 1 | 363742.42 | 4897606.91 | 3.50 | 0 | 63 | 59.8 | 59.8 | 0.0 | 0.0 | 63.6 | 0.1 | -4.3 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 0.4 | 0.4 |
| 2 | 363742.42 | 4897606.91 | 3.50 | 0 | 125 | 73.9 | 73.9 | 0.0 | 0.0 | 63.6 | 0.2 | 3.1 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 7.0 | 7.0 |
| 3 | 363742.42 | 4897606.91 | 3.50 | 0 | 250 | 86.0 | 86.0 | 0.0 | 0.0 | 63.6 | 0.5 | 1.7 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 20.3 | 20.3 |
| 4 | 363742.42 | 4897606.91 | 3.50 | 0 | 500 | 80.6 | 80.6 | 0.0 | 0.0 | 63.6 | 0.8 | -1.3 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 17.4 | 17.4 |
| 5 | 363742.42 | 4897606.91 | 3.50 | 0 | 1000 | 72.1 | 72.1 | 0.0 | 0.0 | 63.6 | 1.6 | -1.3 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 8.2 | 8.2 |
| 6 | 363742.42 | 4897606.91 | 3.50 | 0 | 2000 | 74.6 | 74.6 | 0.0 | 0.0 | 63.6 | 4.1 | -1.3 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 8.1 | 8.1 |
| 7 | 363742.42 | 4897606.91 | 3.50 | 0 | 4000 | 84.9 | 84.9 | 0.0 | 0.0 | 63.6 | 14.0 | -1.3 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | 8.5 | 8.5 |
| 8 | 363742.42 | 4897606.91 | 3.50 | 0 | 8000 | 70.4 | 70.4 | 0.0 | 0.0 | 63.6 | 50.0 | -1.3 | 0.0 | 0.0 | 0.0 | 0.0 | -0.0 | -42.0 | -42.0 |



Suite 500, 4342 Queen Street
Niagara Falls, Ontario, Canada L2E 7J7
Tel 905 374 5200 ♦ Fax 905 374 1157